



Model: **Maxim10**  
**Temporary Lighting System**

Approval No. NSW22910

**230-240V 50Hz**

**10 x 10 Watt 1200lm LED**

**Ta: 25°C**

**LAMP IS NOT REPLACEABLE**

**No user serviceable parts**

**IP65 Ingress Protection**

**Compliant to:**

**AS/NZS 3012:2019+ A1:2020**



**PTO**

## **CAUTION**

- Remove from packaging and position in place before connecting to power
- AS/NZS3012 requirement: String Lighting shall be supported at least 2.5m above any floor ground or platform or be installed immediately below a ceiling
- Install on 230-240V 50Hz power supply
- Use of a Residual Current Device is required for safety, Max 30mA
- Do not use when damaged
- Do not electrically connect to another lighting chain
- UV Protected for use as a temporary lighting system
- This lighting system is intended for outdoor use, but the plug must be used in a weatherproof enclosure.

**PTO**